



“KRAUSENS BALTIJA” SIA

PVN № 50003393971

Ofiss : Bauskas iela 20, LV-1004, Rīga

Fakss, Tālr. +371-67621791, 29509097

RIETUMU BANKA, LV 90 RTMB 0000 059801679

KRAUSENS BALTIJA MEMBRANES

Model	Active Membrane Area ft2(m2)	Operation Pressure Psi (Mpa)	Average FlowRate GP D (m3/d)	Rejection Rate (%)	Recovery Rate (%)
Membrane 50 GPD	4 (0,4)	65 (0,45)	60 (204)	97	15
Membrane 75 GPD	4 (0,4)	65 (0,45)	75 (283)	97	15
Membrane 100 GPD	5 (0,5)	65 (0,45)	100 (378)	97	15
Membrane 400 GPD	16 (1,5)	65 (0,45)	400 (1514)	97	15

Model	Rejection Rate (%)	Rejection Rate (GPD)	Testing Pressure (PSI)
Krausen BW - 4040	99,5	2400	225
Krausen TW – 4040	99	2600	110
Krausen LP – 4040	99,5	2700	150